

# ENERGY STAR<sup>®</sup>

## Residential New Construction Programs

### Historical Document

This document is provided for reference because it has been superseded by a more recent Version or Revision. Please find current program documents on the [Program Requirements](#) webpage.

Use of older Versions and Revisions, such as this document, are typically limited to homes and buildings with a permit date (or, for manufactured homes, a production date) prior to a specified date. Consult the [Implementation Timeline](#) table to assess whether a home or apartment is still eligible to be certified using this document.

For questions or more information, contact us at [energystarhome@energystar.gov](mailto:energystarhome@energystar.gov).



# National ERI Target Procedure

## ENERGY STAR Certified Homes, Version 3 (Rev. 09)

This document provides instructions for determining the ENERGY STAR ERI Target, the highest ERI value that each rated home may achieve to earn the ENERGY STAR. Note that, in addition to meeting the ENERGY STAR ERI Target, homes shall also meet all mandatory Requirements for All Certified Homes in Exhibit 2 of the National Program Requirements for ENERGY STAR Certified Homes, Version 3.

A Home Energy Rating Software program accredited by an EPA-Approved Verification Oversight Organization shall automatically determine (i.e., without relying on a user-configured ENERGY STAR Reference Design) this target for each rated home using the following procedure:

1. The software shall configure the ENERGY STAR Reference Design Home in accordance with Exhibit 2, The Expanded ENERGY STAR Reference Design Definition, and calculate its associated ERI value.
2. For all single-family detached homes, townhomes, rowhomes, duplexes, triplexes, and quadplexes, the software shall calculate the Size Adjustment Factor (SAF) using the following equation:

$$SAF = [CFA_{\text{Benchmark Home}} / CFA_{\text{Home To Be Built}}]^{0.25}, \text{ not to exceed } 1.0$$

Where:

$CFA_{\text{Benchmark Home}}$  = Conditioned Floor Area of the Benchmark Home, using Exhibit 1 below

$CFA_{\text{Home to be Built}}$  = Conditioned Floor Area of the Home to be Built

For the purposes of this step, the software shall calculate the number of bedrooms and the CFA of the home to be built in accordance with the definitions in ANSI / RESNET / ICC Std. 301<sup>1</sup> with the following exception: floor area in basements with at least half of the gross surface area of the basement's exterior walls below grade shall not be counted. <sup>2</sup> Because the SAF cannot exceed 1.0, it only modifies the ERI Target for homes with conditioned floor area greater than the Benchmark Home. For condos and apartments in multi-family buildings the SAF shall always equal 1.0.

3. The software shall calculate the ENERGY STAR ERI Target, rounded to the nearest whole number:

$$ENERGY\ STAR\ ERI\ Target = ERI\ of\ ENERGY\ STAR\ Reference\ Design\ Home \times SAF$$

### Exhibit 1: Benchmark Home Size <sup>3,4</sup>

Bedrooms in Home to be Built	0	1	2	3	4	5	6	7	8
Conditioned Floor Area <small>Benchmark Home</small>	1,000	1,000	1,600	2,200	2,800	3,400	4,000	4,600	5,200



# National ERI Target Procedure ENERGY STAR Certified Homes, Version 3 (Rev. 09)

## Exhibit 2: Expanded ENERGY STAR Reference Design Definition

Building Component	Expanded ENERGY STAR Reference Design Definition <sup>5,6</sup>									
Foundations:	Construction Type & Structural Mass: Same as Rated Home, except: <ul style="list-style-type: none"> <li>For masonry floor slabs, modeled with 80% of floor area covered by carpet and 20% of floor directly exposed to room air</li> </ul>									
	Conditioning Type: Same as Rated Home, except: <ul style="list-style-type: none"> <li>Crawlspaces shall be modeled as vented with net free vent aperture = 1sq. ft. per 150 sq. ft. of crawlspace floor area</li> </ul>									
	Gross Area: Same as Rated Home									
	Insulation: <sup>7,8</sup> Choose appropriate insulation level below; <ul style="list-style-type: none"> <li>Basement Wall Assembly U-factor only applies to conditioned bsmt.'s; if applicable, insulation shall be located on interior side of walls</li> <li>Floor assemblies above crawlspace foundations shall be configured to meet the applicable floor assembly U-factor listed in the building component section for Floors Over Unconditioned Spaces</li> <li>Slab floors with a floor surface less than 12" below grade shall be insulated to the Slab Insulation R-value. The insulation shall extend downward from the top of the slab on the outside of the foundation wall and then vertically below-grade to the Slab Insulation Depth</li> </ul>									
	<b>Climate Zone:</b>		<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>
<b>Slab Insulation R-Value:</b>		0	0	0	10	10	10	10	10	
<b>Slab Insulation Depth (ft):</b>		0	0	0	2	2	4	4	4	
<b>Basement Wall Assembly U-Factor:</b>		0.360	0.360	0.091	0.059	0.059	0.050	0.050	0.050	
Floors Over Unconditioned Spaces:	Construction Type: Wood frame									
	Gross Area: Same as Rated Home									
	Insulation: <sup>7,8</sup>									
	<b>Climate Zone:</b>		<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>
<b>Floor Assembly U-Factor:</b>		0.064	0.064	0.047	0.047	0.033	0.033	0.028	0.028	
Above-Grade Walls:	Interior and Exterior Construction Type: Wood frame									
	Gross Area: Same as Rated Home									
	Solar Absorptance = 0.75									
	Emittance = 0.90									
	Insulation: <sup>7</sup>									
<b>Climate Zone:</b>		<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>	
<b>Wall Assembly U-Factor:</b>		0.082	0.082	0.082	0.082	0.057	0.057	0.057	0.057	
Thermally Isolated Sunrooms:	None									
Doors:	Area: Same as Rated Home									
	Orientation: Same as Rated Home									
	U-Values and SHGCs, based on ENERGY STAR doors: <sup>9</sup>									
	<b>Door Type:</b>		<b>Opaque</b>			<b>≤ 1/2-Lite</b>		<b>&gt; 1/2-Lite</b>		
	<b>U-Value:</b>		0.21			0.27		0.32		
<b>SHGC:</b>		N/A			0.30		0.30			
Glazing:	Total Area: (except in homes with conditioned basements and attached homes <sup>10</sup> ) <ul style="list-style-type: none"> <li>Same as Rated Home, where Rated Home glazing area is less than 15% of conditioned floor area; <u>OR</u></li> <li>15% of the conditioned floor area, where the Rated Home glazing area is 15% or more of the conditioned floor area</li> </ul>									
	Orientation: Equally distributed to North, East, South, and West									
	Interior Shade Coefficient: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC Std. 301 <sup>1</sup>									
	External Shading: None									
	U-Values and SHGCs, based on ENERGY STAR Windows: <sup>9</sup>									
	<b>Climate Zone:</b>		<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>
	<b>U-Value:</b>		0.60	0.60	0.35	0.32	0.30	0.30	0.30	0.30
	<b>SHGC:</b>		0.27	0.27	0.30	0.40	0.40	0.40	0.40	0.40
Skylights:	None									
Ceilings:	Construction Type: Wood frame									
	Gross Area: Same as Rated Home									
	Insulation: <sup>7</sup>									
	<b>Climate Zone:</b>		<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>
<b>Ceiling Assembly U-Factor:</b>		0.035	0.035	0.035	0.030	0.030	0.026	0.026	0.026	
Attics:	Construction Type: Vented with aperture = 1sq. ft. per 300 sq. ft. ceiling area									
	Radiant Barrier: In climate zones 1-3, if > 10 linear ft. of ductwork are located in unconditioned attic									
Roofs:	Construction Type: Composition shingle on wood sheathing									
	Gross Area: Same as Rated Home									
	Solar Absorptance = 0.92									
	Emittance = 0.90									



# National ERI Target Procedure ENERGY STAR Certified Homes, Version 3 (Rev. 09)

## Exhibit 2: Expanded ENERGY STAR Reference Design Definition (Continued)

Heating Systems:	Heating capacity shall be selected in accordance with ACCA Manual S based on building heating and cooling loads calculated in accordance with ACCA Manual J, Eighth Edition, ASHRAE Handbook of Fundamentals, or an equivalent computation procedure.								
	Fuel Type: Same as Rated Home <sup>11</sup>								
	System Type: Same as Rated Home, except Reference Design shall be configured with air-source heat pump in CZ 1-6 where Rated Home is modeled with ground-source heat pump, electric strip or baseboard heat, and Reference Design shall be configured with ground-source heat pump in CZ 7 & 8 where Rated Home is modeled with air-source or ground-source heat pump, electric strip or baseboard heat; applicable efficiency selected from below <sup>12</sup>								
	<b>Climate Zone:</b>	<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>
	<b>Gas Furn. AFUE:</b>	80	80	80	90	90	90	90	90
	<b>Oil Furn. AFUE:</b>	80	80	80	85	85	85	85	85
<b>Gas / Oil Boiler AFUE:</b>	80	80	80	85	85	85	85	85	
<b>Air-Source Heat Pump HSPF:</b>	8.2	8.2	8.2	8.5	9.25	9.5	n/a	n/a	
<b>Air-Source Heat Pump Backup:</b>	Electric	Electric	Electric	Electric	Electric	Electric	n/a	n/a	
<b>Ground-Source Heat Pump COP:</b>	n/a	n/a	n/a	n/a	n/a	n/a	3.5	3.5	
For non-electric warm furnaces and non-electric boilers, the Electric Auxiliary Energy shall be determined in accordance with the methodology for the Energy Rating Reference Home in ANSI / RESNET / ICC Std. 301, using the capacity determined in this Section. <sup>1</sup>									
Cooling Systems:	Cooling capacity shall be selected in accordance with ACCA Manual S based on building heating and cooling loads calculated in accordance with ACCA Manual J, Eighth Edition, ASHRAE Handbook of Fundamentals, or an equivalent computation procedure.								
	Fuel Type: Same as Rated Home <sup>11</sup>								
	System Type: Same as Rated Home, except Reference Design shall be configured with air-source heat pump in CZ 1-6 where Rated Home is modeled with ground-source heat pump and Reference Design shall be configured with ground-source heat pump in CZ 7 & 8 where Rated Home is modeled with air-source or ground-source heat pump; applicable efficiency selected from below <sup>13</sup>								
	<b>Climate Zone:</b>	<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>
	<b>AC SEER:</b>	14.5	14.5	14.5	13	13	13	13	13
	<b>Air-Source Heat Pump SEER:</b>	14.5	14.5	14.5	14.5	14.5	14.5	n/a	n/a
<b>Ground-Source Heat Pump EER:</b>	n/a	n/a	n/a	n/a	n/a	n/a	16.1	16.1	
Service Water Heating Systems:	Use (Gallons per Day): Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC Std. 301, except for reduced usage resulting from the dishwasher specified in the Light, Appliances, & Internal Gains Section. <sup>1, 14</sup>								
	Tank Temperature: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC Std. 301. <sup>1</sup>								
	Fuel Type: Same as Rated Home <sup>11</sup>								
	System Type: Conventional storage water heater with tank size equal to that of Rated Home, unless Rated Home uses instantaneous water heater in which case select 50 gallon tank for gas systems and 60 gallon tank for electric systems. Select applicable efficiency from below using tank size of Reference Home.								
	<b>Gas Storage Tank Capacity:</b> <sup>15</sup>	<b>30 Gallon</b>	<b>40 Gallon</b>	<b>50 Gallon</b>	<b>60 Gallon</b>	<b>70 Gallon</b>	<b>80 Gallon</b>		
	<b>Gas DHW EF:</b>	0.63	0.61	0.59	0.57	0.55	0.53		
	<b>Electric Storage Tank Capacity:</b> <sup>15</sup>	<b>30 Gallon</b>	<b>40 Gallon</b>	<b>50 Gallon</b>	<b>60 Gallon</b>	<b>70 Gallon</b>	<b>80 Gallon</b>		
	<b>Electric DHW EF:</b>	0.94	0.93	0.92	0.91	0.90	0.89		
<b>Oil Storage Tank Capacity:</b> <sup>15</sup>	<b>30 Gallon</b>	<b>40 Gallon</b>	<b>50 Gallon</b>	<b>60 Gallon</b>	<b>70 Gallon</b>	<b>80 Gallon</b>			
<b>Oil DHW EF:</b>	0.55	0.53	0.51	0/49	0.47	0.45			
Thermal Distribution Systems:	Duct Leakage to Outside: The greater of 4 CFM25 per 100 sq. ft. of conditioned floor area or ≤ 40 CFM25.								
	Duct Insulation: • R-8 on supply ducts located in unconditioned attic • R-6 on all other ducts located in unconditioned spaces								
	Duct Surface Area: Same as Rated Home								
	Supply and Return Duct Locations shall be configured according to the table below or, if Rated home does not meet any of the conditions below (e.g. multifamily dwelling unit with conditioned unit below), then duct locations shall be configured to be 100% in attic space.								
	<b>Foundation Type:</b>	<b>Slab</b>		<b>Crawlspace</b>			<b>Basement</b>		
	<b>One Story Above-Grade:</b>	100% Attic		100% Crawlspace			100% Basement		
<b>Two Story Above-Grade:</b>	75% Attic / 25% Conditioned		50% Attic / 50% Crawlspace			50% Attic / 50% Basement			
Thermostat:	Type: Programmable								
	Temperature Setpoints: Same as Energy Rating Reference Home, but with offsets for a programmable thermostat, as defined by ANSI / RESNET / ICC Std. 301 <sup>1</sup>								
Infiltration & Mechanical Ventilation:	Infiltration <b>Climate Zone:</b>								
	<b>Rates:</b>	<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>
	<b>ACH50:</b>	6	6	5	5	4	4	4	3
	Mechanical ventilation system without heat recovery								
	Rate: CFM = 0.01 * CFA + 7.5 * (Nbr + 1), where CFA = Conditioned Floor Area and Nbr = Number of Bedrooms								
	Hours per Day: 24								
Fan Watts: Watts = CFM Rate / 2.2 CFM per Watt, where CFM Rate is determined above									
<b>Climate Zone:</b>	<b>CZ 1</b>	<b>CZ 2</b>	<b>CZ 3</b>	<b>CZ 4</b>	<b>CZ 4 C &amp; 5</b>	<b>CZ 6</b>	<b>CZ 7</b>	<b>CZ 8</b>	
<b>Ventilation Type:</b>	Supply	Supply	Supply	Supply	Exhaust	Exhaust	Exhaust	Exhaust	
Lighting, Appliances, & Internal Gains:	Lighting: Fraction of qualifying Tier I fixtures to all fixtures in qualifying light fixture locations: 80% for interior; 0% for exterior and garage								
	Refrigerator: 423 kWh per year								
	Dishwasher: 0.66 EF, Place Setting Capacity Same as Rated Home								
	Ceiling Fan: 122 CFM per Watt; Quantity = Number of bedrooms + 1 when ceiling fans present in Rated home; otherwise Quantity = 0								
	Clothes Washer and Dryer: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC Std. 301 <sup>1</sup>								
	Internal Gains: Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC Std. 301, except for adjustments for the lighting, refrigerator, dishwasher, and ceiling fans specified in this Section. <sup>1</sup>								
Internal Mass:	Same as Energy Rating Reference Home, as defined by ANSI / RESNET / ICC Std. 301. <sup>1</sup>								
	Additional mass specifically designed as a Thermal Storage Element for the Rated Home shall be excluded.								



# National ERI Target Procedure

## ENERGY STAR Certified Homes, Version 3 (Rev. 09)

### Footnotes:


1. The version of ANSI / RESNET / ICC Std. 301 utilized by RESNET for HERS ratings shall be used to configure this parameter.
2. To determine whether at least half of the basement wall area is below grade, use the gross surface area of the walls that are in contact with either the ground or ambient outdoor air, measured from the basement floor to the bottom of the basement ceiling framing (e.g., the bottom of the joists for the floor above). Note that the exception regarding the floor area in basements is only for the purpose of determining a home's Benchmark Home Size and Size Adjustment Factor. The full conditioned floor area should be used when rating the home (e.g., determining compliance with duct leakage requirements).
3. The average-size home with a specific number of bedrooms is termed the "Benchmark Home". A bedroom is defined by ANSI / RESNET / ICC Std. 301-2014 as a room or space 70 sq. ft. or greater size, with egress window and closet, used or intended to be used for sleeping. A "den", "library", or "home office" with a closet, egress window, and 70 sq. ft. or greater size or other similar rooms shall count as a bedroom, but living rooms and foyers shall not.

An egress window, as defined in 2009 IRC section R310, shall refer to any operable window that provides for a means of escape and access for rescue in the event of an emergency. The egress window definition has been summarized for convenience. The egress window shall:

- have a sill height of not more than 44 in. above the floor; AND
  - have a minimum net clear opening of 5.7 sq. ft.; AND
  - have a minimum net clear opening height of 24 in.; AND
  - have a minimum net clear opening width of 20 in.; AND
  - be operational from the inside of the room without the use of keys, tools or special knowledge.
4. The conditioned floor area of a Benchmark Home (CFA Benchmark Home) is determined by selecting the appropriate value from Exhibit 1. For homes with more than 8 bedrooms, the CFA Benchmark Home shall be determined by multiplying 600 sq. ft. by the total number of bedrooms and adding 400 sq. ft.

Example: CFA Benchmark Home for a 10 bedroom home = (600 sq. ft. x 10) + 400 sq. ft. = 6,400 sq. ft.

5. Any parameter not specified in this exhibit shall be set to "Same as Rated Home".
6. The following map is shown to depict Climate Zone boundaries. It is for illustrative purposes only and is based on 2009 IECC Figure 301.1.



7. For informative purposes, assembly U-factors are meant to correlate to typical assemblies containing the nominal R-values as listed in 2009 IECC Table 402.1.1.
8. If software allows the user to specify the thermal boundary location independent of the conditioned space boundary in the basement of the rated home, then the thermal boundary of the ENERGY STAR Reference Design shall be aligned with this boundary. For example, if the thermal boundary is located at the walls, then the wall insulation shall be configured as if it was a conditioned basement. If the thermal boundary is located at the floor above the basement, then the floor insulation shall be configured as if it was a floor over an unconditioned space.
9. All Reference Design window and door U-value and SHGC requirements are based on the ENERGY STAR Program Requirements for Residential Windows, Doors, and Skylights – Version 5.0 as outlined at [www.energystar.gov/windows](http://www.energystar.gov/windows), except that SHGC values have been assumed for CZ 4 C & 5-8. Note that the U-factor requirement applies to all fenestration while the SHGC only applies to the glazed portion.



# National ERI Target Procedure ENERGY STAR Certified Homes, Version 3 (Rev. 09)

10. When determining the ENERGY STAR ERI Target for homes with conditioned basements and for attached homes, the following formula shall be used to determine total window area of the ENERGY STAR Reference Design:

$$AG = 0.15 \times CFA \times FA \times F$$

Where:

- AG = Total glazing area
- CFA = Total conditioned floor area
- FA = (Gross above-grade thermal boundary wall area) / (Gross above-grade thermal boundary wall area + 0.5 x Gross below-grade thermal boundary wall area)
- F =  $1 - 0.44 \times (\text{Gross common wall area}) / (\text{Gross above-grade thermal boundary wall area} + \text{Gross common wall area})$

And where:

- Thermal boundary wall is any wall that separates Conditioned Space from Unconditioned Space, outdoor environment, or the surrounding soil;
  - Above-grade thermal boundary wall is any portion of a thermal boundary wall not in contact with soil;
  - Below-grade thermal boundary wall is any portion of a thermal boundary wall in soil contact; and
  - Common wall is the total wall area of walls adjacent to another conditioned living unit, not including foundation walls.
11. In the ENERGY STAR Reference Design, fuel type(s) shall be same as Rated Home, including any dual-fuel equipment where applicable. For a Rated Home with multiple heating, cooling, or water heating systems using different fuel types, the applicable system capacities and fuel types shall be weighted in accordance with the loads distribution (as calculated by accepted engineering practice for that equipment and fuel type) of the multiple systems.
12. For a Rated Home without a heating system, the ENERGY STAR Reference Design Home shall be configured with a 78% AFUE gas furnace system, unless the Rated home has no access to natural gas or fossil fuel delivery. In such cases, the ENERGY STAR Reference Design Home shall be configured with a 7.7 HSPF air-source heat pump.
13. For a Rated Home without a cooling system, the ENERGY STAR Reference Design Home shall be configured with a 13 SEER electric air conditioner.
14. That is to say, representative of standard-flow plumbing fixtures, reference clothes washer gallons per day, standard distribution system water use effectiveness, a hot water piping ratio of 1.0, no pipe insulation, and no drainwater heat recovery.
15. To determine domestic hot water (DHW) EF requirements for additional tank sizes, use the following equations: Gas DHW EF  $\geq 0.69 - (0.002 \times \text{Tank Gallon Capacity})$ ; Electric DHW EF  $\geq 0.97 - (0.001 \times \text{Tank Gallon Capacity})$ ; Oil DHW EF  $\geq 0.61 - (0.002 \times \text{Tank Gallon Capacity})$ .